File Original and First Copy with Department of Ecology Second Copy — Owner's Copy Second Copy - Owner's Cop Third Copy - Driller's Copy

## WATER WELL REPORT

STATE OF WASHINGTON P O Box 657 Stanwood Wa. 98292 (1) OWNER: Name New Utsalady Water System Inc. N.E., N.W. 4 Sec 19 T32 N R3 (2) LOCATION OF WELL: County Island Bearing and distance from section or subdivision corner (10) WELL LOG: (3) PROPOSED USE: Domestic F Industrial 

Municipal Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation. Irrigation | Test Well | ė Other Owner's number of well (if more than one)..... (4) TYPE OF WORK: MATERIAL New well Method: Dug Bored [ 110 Sand Gravel Driven 🗆 Cable  $\square$ Deepened 110 118 Sand & Water Rotary Jetted | Reconditioned [ 118 125 Gravel & Water (5) DIMENSIONS: Diameter of well ... Greenish Blue Clay Drilled 136 ft. Depth of completed well 135 ft. (6) CONSTRUCTION DETAILS: Casing installed: 6 "Diam from O rt. to 120 ft. " Diam. from ..... ft. to ..... ft. Perforations: Yes 🗆 No 🗗 Type of perforator used..... SIZE of perforations ..... in, by ..... in. .... perforations from ...... ft. to ..... ft. perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. perforations from ...... ft. to ...... ft. Screens: Yes No 🗆 Manufacturer's Name JOANSON Type 55 Model No.
Diam. 5 Slot size 5 from 120 ft. to 125 ft. Diam. . . . . Slot size . . . . . from . . . . . ft. to . . . . . . ft. Gravel packed: Yes | No | Size of gravel: Gravel placed from ...... ft. to ..... ft. to ..... ft. Surface seal: Yes No 🗆 Did any strata contain unusable water? Yes Type of water?..... Depth of strata...... Method of sealing strata off...... (7) PUMP: Manufacturer's Name... Туре: ..... Н.Р..... Land-surface elevation above mean sea level.... (8) WATER LEVELS: ft. below top of well Date 6-15 Artesian water is controlled by (Cap, valve, etc.) Drawdown is amount water level is lowered below static level No If yes, by whom the ft, drawdown after Work started. Completed Was a pump test made? Yes Yield: 2 gal/min. with WELL DRILLER'S STATEMENT: hrs. This well was drilled under my jurisdiction and this report is .. true to the best of my knowledge and belief. Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level) NAME Dahlman Pump & Well Drilling Inc. Time Water Level Time Water Level (Person, firm, or corporation) (Type or print) Time Address P O Box 422 Burlington Wa. 98233 A Beller test 50 gal/min, with 30 ft. drawdown after..... Artesian flow......g.p.m. Date.... License No. 0623 Date 6-15- 19.87 Temperature of water Was a chemical analysis made? Yes No